



EUROVENT
CERTIFIED
PERFORMANCE

ENERGY (Y) (U) (A) (E) (IA) EFFICIENCY CLASS

AAF

DriPak®

NX, 592x592x640-10

www.eurovent-certification.com

AIR FILTERS

Luftfilter

F9

EN779:2012

Nominal airflow:	3400	m ³ /h
Initial efficiency 0.4 µm:	80	%
Minimum efficiency 0.4 µm:	80	%
Annual Energy Consumption: From	0	kWh/annum
To	2000	kWh/annum

